

ings shall slope downward from building foundations and water supply wells to lower areas to insure flow of water away from the structure."

Section 3-208 (157).

Immediately below Subsection 1309.2 of the Fourth Edition of the BOCA Basic Building Code, add the following new Subsections: "Subsection 1309.3. Removal of Building Debris. No scrap wood, form materials or other debris subject to decomposition shall be buried or left under floors, porches or around foundation walls."

Section 3-208 (158).

Immediately below Subsection 1309.2 of the Fourth Edition of the BOCA Basic Building Code (as amended by Section 3-208 (157) of this ordinance) add a new Subsection 1309.4 to read as follows: "Subsection 1309.4. Driveways. Driveways, when installed, shall extend from street or alley pavement to garage, carport or parking space. The minimum width shall be eight (8) feet. The maximum gradient between vertical transitions shall be twenty percent (20%). The vertical transition shall prevent contact of car undercarriage or bumper with the driveway surfaces. Alignment shall be safe and convenient to back a car out or an adequate turn-around shall be provided."

Section 3-208 (159).

Immediately below Subsection 1502.1 of the Fourth Edition of the BOCA Basic Building Code, add the following new Subsection 1502.3: "Subsection 1502.3. Grounding Electrode. In order to provide an adequate electrical ground for those structures which do not have water provided by a metallic water service line (public or private) a grounding electrode shall be provided. This shall consist of a minimum horizontal length of TWENTY (20) FEET bare copper conductor placed along the bottom of the footing excavation prior to pouring of the concrete. The conductor will be located nearest the expected electric lead in to the building by the utility company, and will be extended so as to provide a minimum of six (6) inches of wire above the finished grade on the outside of the foundation wall. The electrode size in diameter shall be as follows:

<i>Service Equipment</i>	<i>Size Wire</i>
0 to 200 Amperes	#4
Over 200 to 300 Amp.	#2
Over 300 to 400 Amp.	#1/0
Over 400 to 600 Amp.	#2/0
Over 600 Amp.	#3/0

Section 4. AND BE IT FURTHER ENACTED, That this Ordinance shall take effect forty-five (45) days from the date it becomes law.

READ AND PASSED this 15th day of September, 1969.

By Order: Evelyn M. Boettcher, Secretary

PRESENTED to the County Executive for his approval this 17th day of September, 1969.

Evelyn M. Boettcher, Secretary

APPROVED AND ENACTED: September 24, 1969.

Joseph W. Alton, Jr.
County Executive